

Gas Ducting



Both the **National Grid** and **Wales & West Utilities** specify that in most cases, ducting for gas main service pipes must be yellow in colour, perforated and conform to **BS4962**. Advice should be sought from the local utility company as to the appropriate duct diameter.

Unperforated options which conform to **BS EN 61386-24 2010** are available in various sizes should that be specified instead of perforated.

Size	Length	Perf	Solid
60mm (o.d)	50m	✓	✗
100mm (o.d)	50m	✓	✗
160mm (o.d)	35m	✓	✗
50mm (i.d)	50m	✗	✓
94mm (i.d)	6m or 50m	✗	✓
150mm (i.d)	6m	✓	✓
225mm (i.d)	6m	✓	✓
300mm (i.d)	6m	✓	✓
450mm (i.d)	6m	✓	✓

